

# PORTLAND CEMENT CONCRETE PLANT EVALUATION

EFFECTIVE DATE: 5/21/13

Submitted on Mainframe

<u>Code</u>	<u>Sticker Expires</u>	<u>Plant Location</u>	<u>Rating</u>	<u>Std. Dev</u>	<u>Comments</u>	<u>Dist.</u>
A072A	7/15/13	Adams Trucking Barboursville, WV	A-2	948.4	Class B w/FA (6.00 bags) reduce to 5.50 bags	2
A104A	11/7/13	New Castle Morgantown, WV	A-2	650.0	Maintain current design cement factors	4
A104B	6/3/13	Essroc Ready Mix Gallipolis, OH	A-2	650.0	Class B w/FA (6.00 bags) reduce to 5.50 bags Maintain current design cement factors	2
A104C	11/17/13	Essroc Ready Mix New Martinsville, WV	A-2	650.0	Maintain current design cement factors	6
A104E	11/17/13	Essroc Ready Mix McMechen, WV	A-2	696.3	Class B w/FA (6.00 bags) reduce to 5.50 bags Maintain current design cement factors	6
A104H	8/8/13	Essroc Ready Mix Winfield, WV	A-2	744.1	Class B w/FA (6.00 bags) reduce to 5.50 bags Maintain current design cement factors	1
A104L	7/29/13	Essroc Ready Mix Parkersburg, WV	A-2	912.6	Class B w/FA (6.00 bags) reduce to 5.50 bags Maintain current design cement factors	3
A128A	9/13/12	Central Supply Lorentz, WV	B	650.0	Maintain current design cement factors	7
A291A	10/10/13	Valley Concrete Wheeling, WV	A-2	650.0	Maintain current design cement factors	6
B219B	4/20/12	Boxley Materials Beckley, WV	B	697.7	Maintain current design cement factors	10
B219C	10/23/13	Boxley Materials Alta, WV	A-2	799.4	No design data submitted	9
B219D	7/30/12	Boxley Materials Beckley, WV	B	764.0	No design data submitted	10
C089F	7/6/13	Central Supply Saltwell, WV	A-2	827.9	Maintain current design cement factors	4
C089G	7/3/12	Central Supply Morgantown, WV	B	794.0	Maintain current design cement factors	4
C089H	10/17/13	Central Supply Meadowbrook, WV	A-2	650.0	No design data submitted	4

D069B	2/5/13	D.W. Dickey Concrete Steubenville, OH	B	650.0	Maintain current design cement factors	6
D069E	8/26/13	D.W. Dickey Concrete East Liverpool, OH	A-2	650.0	No design data submitted	6
D156A	8/14/13	Dan Lee Co. Concrete Inwood, WV	A-2	650.0	No design data submitted	4
E016O	9/5/13	Central Supply Elkins, WV	A-2	848.2	Maintain current design cement factors	8
F011E	9/29/13	Fairfax Concrete Thomas, WV	A-2	650.0	No design data submitted	5
F011F	10/9/13	Fairfax Concrete Oakland, MD	A-2	650.0	No design data submitted	5
F011G	8/6/13	Allegany Concrete Short Gap, WV	A-2	648.0	Class B mod 4500 (7.00 bags) increase to 7.25 bags Class B 3000w/GBFS (6.00 bags) reduce to 5.50 bags Maintain current design cement factors	5
F011J	10/1/13	Fairfax Concrete Scherr, WV	A-2	783.4	Class B 3000w/GBFS (6.00 bags) reduce to 5.50 bags Maintain current design cement factors	5
G005A	10/26/13	Golden Triangle Mt. Storm, WV	A-2	650.0	No design data submitted	5
G023O	11/1/13	Greenbrier Ready Mix Caldwell, WV	A-2	650.0	No design data submitted	9
G170O	9/26/13	Central Supply Gassaway, WV	A-2	874.2	Maintain current design cement factors	7
G179A	9/20/12	Central Supply Glenville, WV	B	650.0	Maintain current design cement factors	7
H124B	10/13/12	Hi-Way Paving Scherr, WV	B	442.1	No design data submitted	5
L046O	10/23/13	Logan Concrete Logan, WV	A-2	582.2	Class B w/FA (6.00 bags) reduce to 5.50 bags Maintain current design cement factors	2
L144B	10/16/13	Boxley Materials Summersville, WV	A-2	650.0	Maintain current design cement factors	9
L144C	10/30/12	Boxley Materials Wolfpen, WV	B	877.2	Maintain current design cement factors	6

M188O	11/14/12	Madison Ready Mix Madison, WV	B	650.0	No design data submitted	1
M309A	10/24/13	Moore's Ready Mix Greenbank, WV	A-2	650.0	No design data submitted	8
P017A	9/1/13	Essroc Ready Mix Charleston, WV	A-2	826.9	Maintain current design cement factors	1
P197A	11/15/12	Boxley Materials Princeton, WV	B	650.0	Maintain current design cement factors	10
P337A	9/11/13	The Wells Group S. Williamson, WV	A-2	650.0	No design data submitted	2
P337C	9/11/13	The Wells Group Lovely, KY	A-2	650.0	No design data submitted	2
R165A	10/2/13	Rumble Ready Mix Winfield, WV	A-2	650.0	Maintain current design cement factors	1
R165C	10/12/13	Rumble Ready Mix Belle, WV	A-2	650.0	Maintain current design cement factors	1
S049A	9/12/13	Smith Concrete Porterfield, OH	A-2	527.9	Class B (6.00 bags) reduce to 5.50 bags	3
S049B	8/5/13	Smith Concrete Reno, OH	A-2	567.7	Maintain current design cement factors	3
S057O	6/6/13	Superior Supply Caldwell, WV	A-2	650.0	Maintain current design cement factors	9
S174A	10/23/13	Claxton Smith Culloden, WV	A-2	650.0	No design data submitted	1
S174C	10/22/13	Claxton Smith Charleston, WV	A-2	650.0	Maintain current design cement factors	1
S174O	7/9/13	Claxton Smith Poca, WV	A-2	650.0	No design data submitted	1
S371B	8/8/13	Essroc Ready Mix Winfield, WV	A-2	650.0	Maintain current design cement factors	1
S371C	11/13/13	Essroc Ready Mix Huntington, WV	A-2	729.6	Maintain current design cement factors	2
S383B	8/28/13	Cardinal Concrete	A-2	626.3	Maintain current design cement factors	7

Ravenswood, WV

S383C	8/4/13	Cardinal Concrete Parkersburg, WV	A-2	590.1	Maintain current design cement factors	3
T014C	9/3/11	PCI Concrete Martinsburg, WV	B	650.0	Maintain current design cement factors	5
T162A	9/27/13	Tri-Son Concrete Bellaire, OH	A-2	765.9	No design data submitted	6
T176A	7/17/13	The Wells Group Wayne, WV	A-2	650.0	Maintain current design cement factors	2
T184A	9/18/13	Thomas, Bennet, Hunter Martinsburg, WV	A-2	1104.1	Class B 3000 w/GBFS (6.00 bags) reduce to 5.50 bags Maintain current design cement factors	5
U017B	11/15/12	Boxley Materials Bluefield, WV	B	650.0	No design data submitted	10
V072B	5/8/13	Valley Brook Conc. #3 Robertsburg, WV	A-2	650.0	No design data submitted	1
V072C	5/8/13	Valley Brook Conc. #1 Lakin, WV	A-2	650.0	No design data submitted	1
W081A	10/8/13	Weirton Ice & Coal Weirton, WV	A-2	895.8	Class B (6.00 bags) reduce to 5.50 bags	6
W424A	11/6/13	The Wells Group Cannonsburg, KY	A-2	650.0	Maintain current design cement factors	2
W424B	9/12/13	The Wells Group Louisa, KY	A-2	650.0	Maintain current design cement factors	2
W431A	11/14/13	Wrightway Ready Mix Holden, WV	A-2	650.0	No design data submitted	2